

The fourth bullet on page 2-2 of the March 2003 report by Black & Veatch is replaced by the following table:

<b>2007 CBC Earthquake Design Factor</b>	<b>Value</b>
0.2-Second Mapped spectral Acceleration Parameter, $S_s$	2.545
1-Second Mapped Spectral Acceleration Parameter, $S_1$	0.963
Site Class	B
Short Period Site Coefficient, $F_a$	1.0
1-Second Period Site Coefficient, $F_v$	1.0
Short Period Adjusted MCE Spectral Response Acceleration Parameter, $S_{ms}$	2.545
1-Second Period Adjusted MCE Spectral Response Acceleration Parameter, $S_{m1}$	0.963
Short Period Design Spectral Response Acceleration Parameter, $S_{DS}$	1.697
1-Second Period Design Spectral Response Acceleration Parameter, $S_{D1}$	0.642